

Stephen J. Puleo

From: John K. Wescott
Sent: Thursday, April 11, 2024 11:06 AM
To: Stephen J. Puleo
Cc: Brent J. Libby
Subject: Plans Review

Good morning, Steve,

We're all set at the plans for Vintage subdivision as proposed. We're okay with the Betty Lane project with only one exception. We propose the buildings should be sprinkled or a 30,000-gallon underground water cistern to be installed to NFPA 22 Standard. The cistern should be located at the entrance to Betty and Chute Road. Any question give us ring.

John K.Wescott
Deputy Fire Chief
Inspections, Prevention, Operations
CPE-I, CFI-I