

From: Jonathan R. Earle
Sent: Thursday, September 13, 2018 3:18 PM
To: 'Dustin Roma (dustin@dmroma.com)'; Amanda L. Lessard
Subject: 18-28 - Heritage Village Site Plan (Sketch)

Dustin,

In addition to Amanda's comments regarding the project, I would also add:

1. Trip generation would need to be calculated for the purposes of generating the 302 North Road Improvements Impact Fee.
2. Will the existing water service be used to serve the expansion?
3. Provide septic design for the new disposal system in the parking lot once it is available.

Jon

Jon Earle, PE
Town Engineer
Town of Windham

Office: (207) 894-5900, ext. 6124

Cell: (207) 212-1802

www.windhammaine.us