

FairPoint

APPLICATION FOR POLE LOCATIONS

February 9, 2018

To the Board of Councilors
of Windham, Maine

NORTHERN NEW ENGLAND TELEPHONE OPERATIONS LLC and **CENTRAL MAINE POWER COMPANY** respectfully request(s) permission for a location for poles and cables and wires thereon, including the necessary sustaining, supporting and protecting fixtures in, along, upon and across the following named public streets and highways:


IN THE TOWN OF WINDHAM, MAINE

Roosevelt Trail / US Rte 302 (Compact area) – Placement of new Pole 607 ½X [239H] approximately 705 feet Southerly of the intersection of center line of River Road, one pole

THIS APPLICATION IS BEING SUBMITTED WITHOUT PUBLIC NOTICE BY PUBLICATION


Said poles to be erected substantially in accordance with the plan filed herewith marked FairPoint. No. **318042** dated January 26, 2018 and shall be of wood or other suitable material, and the cables and wires shall be run at the height in compliance with standards of the National Electrical Safety Code at highway crossings and elsewhere for electric cables and wires, and (or) for telephone cables and wires. All cables and wires to be maintained in accordance with standards of the National Electrical Safety Code.

**NORTHERN NEW ENGLAND TELEPHONE
OPERATIONS LLC**

By 

Jessica Theriault
Right of Way

CENTRAL MAINE POWER COMPANY

By 

Herb Stevens
Supervisor – Integrated Field Design

PERMIT FOR POLE LOCATIONS

To the Board of Councilors
Windham, Maine

ORDERED: That NORTHERN NEW ENGLAND TELEPHONE OPERATIONS LLC and CENTRAL MAINE POWER COMPANY be and is/are hereby authorized and permitted to erect and maintain poles and cables and wires to be placed thereon, together with such sustaining, supporting and protecting fixtures as said companies may deem requisite, in, along, upon and across the public streets and highways of said Town of Windham as hereinafter designated, as requested in application of said companies dated the 16th day of February, 2018.

All construction under this permit shall be in accordance with the following specifications: The poles shall be located between the vehicular traveled section of the way and the limits of the highway, shall be set firmly in the ground, substantially at locations indicated upon the plan marked Fairpoint No. 318042 dated January 26, 2018 filed with said application, and shall be of wood or other suitable material, and the cables and wires shall be run at the height in compliance with standards of the National Electrical Safety Code at highway crossings and elsewhere for electric cables and wires, and (or) for telephone cables and wires.

All cables and wires to be maintained in accordance with standards of the National Electrical Safety Code.

Following are the public streets and highways above referred to:

Roosevelt Trail / US Rte 302 (Compact area) – Placement of new Pole 607 1/2X [239H] approximately 705 feet Southerly of the intersection of center line of River Road, one pole

THIS PERMIT IS BEING GRANTED WITHOUT PUBLIC NOTICE BY PUBLICATION

It is further adjudged and voted that satisfactory proof of validity of the applicant's notice or procedures required by statute has been given upon the application of said companies to erect poles with the cables and wires thereon in, along, upon and across the public streets and highways of Windham, Maine, designated by this permit.

Board of Councilors

1. _____

4. _____

2. _____

5. _____

3. _____

6. _____

PERMIT GRANTED

7. _____

_____, 2018

This permit is recorded in the Records of the Town Clerk of Windham,
Book _____, Page _____

Town Clerk

	SAFETY NOTES:		MOD/REV NO	DATE	EWO NO. 318042
	BEWARE OF TRAFFIC				PRINT 1 OF 1
	SIGNATURE:		TYPE	RECORD REF:	PREPARED BY:
	DATE: 1/26/2018		AERIAL	N/A	MARTIN PEASE
	PRE CT YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	UNDERGROUND	NA	C. O. /EXCHANGE NAME:	WINDHAM
	PRIMARY VOLTAGE TO GROUND	BLOCK (NYT)	N/A	C. O. /EXCHANGE CODE:	7375
	7.2 KV MGN SYSTEM	CONDUIT	N/A	MUNICIPALITY:	WINDHAM
CABLE PRESS	UNDER PRESS YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	BUFFER YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	MANHOLE LOCATION MH N/A		
TRANSMISSION	26 GA LIMIT YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	AMT. BRIDGE TAP	AMT. KF		

