

PLANNING BOARD MEMO • MAJOR SITE PLAN & SUBDIVISION • SKETCH PLAN REVIEW

DATE: July 10, 2025

TO: Windham Planning Board
FROM: Amanda Lessard, Senior Planner/Project Manager
Cc: Steve Puleo, Planning Director
Eric Dube, PE, Trillium Engineering Group
Tyler Monahan, Moon Apartments, LLC

RE: #25-17 209/211 Tandberg Trail Multifamily – Major Subdivision & Site Plan – Sketch Plan Review – 209 & 211 Tandberg Trail – Moon Apartments, LLC
Planning Board Meeting: July 14, 2025

Overview –

The application is for the development of 10 apartments by the conversion of an existing mixed-use building that has 2 existing dwellings and a former daycare at 211 Tandberg Trail to add 2 apartments to create a 4-unit building; and constructing a new 8-unit multifamily building. An existing 2 unit building at 209 Tandberg Trail will remain in place. Subject property is identified on Tax Map: 19C; Lots: 50-C and 50-D; Zone: Commercial IV (C-4) in the Pleasant River watershed.



Figure 1: Aerial View of the subject parcel(s) relative to surrounding properties and street network

A Development Review Team meeting took place on July 7, 2025. Comments received during the meeting are summarized in the memo below.

Note that the application materials includes waiver requests for 120-411.1 E(4) C-4 Minimum Front Setback and 120-814 B 5(b) Multi-family development parking lot landscaping. The Planning Board has no authority to waive zoning district dimensional standards or multifamily development performance standards.

SUBDIVISION/SITE PLAN REVIEW

PLEASE NOTE: The staff memo is a reference guidance document, and suggested topics for board discussion are listed; ~~the strikethrough text is items for the final review;~~ ***bold and italic text represent unaddressed existing and/or new staff comments***; or plain underlined text are items that have been addressed by the applicant; and *italic text is for information or previously reviewed and/or approved items*.

Staff Comments:

1. Complete Application: *N/A with Sketch Plan*

MOTION: ~~[I move] the Major Site Plan & Subdivision application #25-17 209/211 Tandberg Trail Multifamily project is found complete in regard to the submission requirements based on the application checklist, but the Planning Board retains the right to request more information where review criteria are not fully addressed.~~

2. Waivers:

Waiver of Submission Requirements: *The Planning Director, or designee, may waive any of the submission requirements of [§120-811](#) or [§120-910](#) based upon a written request by the applicant. Such a request shall be submitted at the time of the preapplication conference for minor developments or as part of the sketch plan application for major developments. A waiver of any submission requirement may be granted only if the Planning Director, or designee, finds that the information is not required to determine compliance with the standards and criteria of the Land Use Ordinance.*

Waiver of the Site Plan Performance Standards. *The Planning Board may waiver the requirements of [§120-812](#) if it finds that extraordinary an unnecessary hardship, not self-imposed, may result from strict compliance with the site plan review standards. In all cases, waivers shall not be deemed a right of the applicant, but rather shall be granted at the discretion of the Planning Board. The applicant shall submit a list of the requested waiver(s) in writing. For each waiver requested, the applicant shall submit answers to each criterion in [§120-808B\(2\)](#).*

None requested.

Waiver of the Subdivision Performance Standards. *The Planning Board may waive the requirements of [§120-911](#) Performance and Design Standards when the applicants demonstrates that the performance standards of these regulations and the criteria of the subdivision statute have been or will be met, and the public health, safety, and welfare are protected and provided the waivers do not have the effect of nullifying the intent and purpose of the land use ordinance. In granting site waivers, the Planning Board shall utilize the criteria in [§120-908C\(2\)](#).*

a) [§120-911A\(2\)\(a\)](#) Underground Utilities.

The applicant requests a waiver to keep existing overhead utilities to the existing structures. The proposed 8-unit multi-family building will have be served by underground utilities.

STAFF SUPPORT FOR WAIVER: Staff support the waiver for utility service to the existing buildings.

MOTION: ~~[I move] to approve the waiver requests of [§120-911A\(2\)\(a\)](#) Underground Utilities, to waive the requirement for underground utilities for the existing buildings. The Planning Board cannot act on waivers or potential waiver requests at the Sketch/Preapplication review phase. It is appropriate to discuss potential waiver requests to give the applicant guidance.~~

3. Public Hearing: The planning board shall determine whether to hold a public hearing on the preliminary and/or final plan.
4. Site Walk: The planning board shall determine when to schedule a site walk.

Findings of Fact, Conclusions, and Conditions of Approval for the Windham Planning Board:

MOTION: ~~[I move] the Major Site Plan & Subdivision application for the #25-17 209/211 Tandberg Trail Multifamily development identified Tax Map: 19C; Lots: 50 C and 50 D; Zone: Commercial IV (C 4) in the Pleasant River watershed is to be (approved with conditions/denied) with the following Findings of Fact, Conclusions, and Conditions of Approval.~~

FINDINGS OF FACT

Jurisdiction: The 209/211 Tandberg Trail Multifamily development is classified as a Major Site Plan & Subdivision, which the Planning Board is authorized to review and act on by [§120-903](#) and by [§120-803A\(1\)](#) of the Town of Windham Land Use Ordinance.

Title, Right, or Interest: The applicant has submitted a copy of a Quitclaim Deed With Covenant between Dilworth & Sons, LLC and Moon Apartments, LLC dated October 4, 2024, and recorded on October 7, 2024 at the Cumberland County Registry of Deeds in Book 41041 and Page 45.

ARTICLE 3 DEFINITIONS

DWELLING, MULTIFAMILY

A building containing three or more dwelling units. A multifamily dwelling may be attached to a nonresidential use.


ARTICLE 4 ZONING DISTRICTS

- As shown on the Town of Windham [Land Use Map](#) approved by the Town Council, date April 9, 2024, Map 19C; Lots: 50-C and 50-D.
- The property is located in in Commercial IV (C-4) zoning district.
- The minimum lot size [§120-411.1E\(1\)\(a\)](#) for dwellings is 40,000 SF.
- The existing buildings are legally non-conforming with regard to the 40' front setback.
- The State of Maine minimum lot size, and minimum lot size waiver, standards apply in the C-4 District when the Town's minimum lot size requirements are less restrictive than those of the State of Maine.

ARTICLE 5 PERFORMANCE STANDARDS

§120-511 – Buffer yards

C(3)(b) Buffers along streets. Commercial Districts (C-1, C-2, C-3, C-4, VC and WC Districts): use Buffer Yard G, see exhibit below.



§120-541 – Net residential area of acreage

- B. The net residential area or acreage of a lot proposed for subdivision, as defined, shall be calculated by subtracting the eight (8) items listed in the subsection from the gross acreage of a lot and dividing the resulting net residential area of the parcel by the net residential density standard of the appropriate zoning district (see [Article 4](#), Zoning Districts).

§120- 812 – MAJOR SITE PLAN PERFORMANCE STANDARDS

§120-812A – Utilization of the Site

- The subject parcels (the two combined lots) is 70,958 FT (approximately 1.63 acres) in size.
 - At the Development Review Team meeting, the Assessor asked if the two parcels would be combined with one new parcel metes and bounds description. The applicant agreed that could occur post-approval.
- There is an existing mixed-use building that has 2 existing dwellings and a former daycare at 211 Tandberg Trail and an existing 2 unit building at 209 Tanberg Trail.
- The site fronts along Tandberg Trail and has 267 feet of road frontage.

§120-812B – Vehicular Traffic

- (1) The site is located on the southerly side of Tandberg Trail. The applicant is proposing to utilize the existing curb cuts. The entrance at 209 Tandberg Trail serves the existing 2-unit dwelling and shares access with the adjacent gas station/convenience store. The entrance at 211 Tandberg Trail is proposed to meet the Town's "Major Private Road" standard for design and construction. A right-of-way is not required for an access driveway in the Multi-family performance standards, found in [§120-814B\(6\)\(b\)\[2\]](#).

- (a) The applicant does not expect to impact any road intersections within a half mile of the project.
- (b) For the *preliminary plan review*, **If the project generates 50 or more trips during either the a.m. or p.m. peak** hour, per [§120-811B\(2\)\(h\)](#), the applicant shall provide, for the *preliminary plan review*, a “traffic study,” prepared by a Maine licensed professional engineer, describing the impacts of the proposed project on the capacity, level of service and safety of adjacent streets. The applicant shall provide a traffic analysis that the existing streets and intersections can be expected to carry traffic generated by the development.
 - The development is located in the [North Route 302 Road Improvement Impact Fee Collection Area](#), see Conditions of Approval, *if applicable*. Provide an estimate of the number of new peak hour trips expected to pass through the Route 302, Anglers Road and White’s Bridge Road intersection, per [§120-1204J\(1\)](#).
- (2) The access shall be designed to have minimum sight distance, according to MDOT and [Appendix B Street Design and Construction Standards](#), to avoid hazardous conflicts with existing turning movements, to avoid traffic congestion, and to prevent queuing of vehicles entering and exiting the site.
- (3) The proposal site will be accessed from Tandberg Road.
- (4) The site is designed to allow internal vehicular circulation in common with the other property owner for the safe movement of passenger, service, and emergency vehicles through the site.
- **At the Development Review Team meeting the Deputy Fire Chief commented that the building is limited access on all four sides. My recommendation would be to improve the proposed sidewalk on the north side of the building so that fire apparatus can access that side and wrap the parking area around to the south side so we can access the south side. The front parking area also has limited access for the aerial ladder but it is doable. This will at least give access to three sides.**

[§120-812C](#) – Parking and Loading

- (1) The applicant has designed a parking layout that provides 28 parking spaces.

[§120-812D](#) – Pedestrian Traffic

There are no existing sidewalks along the property frontage on Tandberg Trail. Sidewalks are not required for the access drive. The sketch plan proposes an internal sidewalk connection to the convenience store on the abutting property.

[§120-812E](#) – Stormwater Management

- (1) The applicants shall provide for the *preliminary plan review* a stormwater management system design for the collection and disposal of all the stormwater that runs off of parking areas, roofs, travel ways, and other surfaces.
- (f) Major site plans, regardless of size, shall comply with Sections 4C(2) and 4C(3) of the General Standards of the MDEP Chapter 500 Stormwater Management Law.

- The site is located in the Town’s Urbanized Area and regulated by the MS4 ([Municipal Separate Storm Sewer System](#)). The applicant states that the site disturbance is anticipated to be less than an acre and is therefore not subject to the Post-Construction Stormwater Ordinance, [Chapter 201 Article II](#).

§120-812F – Erosion Control

- (2) The applicant shall have provided for the preliminary plan review an erosion and sedimentation control plan that will meet the Basic Standards per Section 4(A) of the MeDEP Chapter 500 Stormwater Rule.

§120-812G – Water Supply Provisions

- (1) The existing buildings are served by a Portland Water District water main.
- The applicant shall provide for *the preliminary plan review* a PWD letter or email stating the system has capacity to serve the new residential development.

§120-812H – Sewage Disposal Provisions

- *For the preliminary plan review*, the applicant will provide an HHE-200 applications for the proposed shared wastewater disposal systems. A waiver will be required from the State Minimum Lot Size.

§120-812I – Utilities

- The applicant all utility connections (electrical, telephone, and telecommunication services) will be subsurface.
- A utility and grading plan shall be provided for *the preliminary plan review*.

§120-812J – Groundwater Impacts

- The building conversion is connected to the PWD public water system, and the wastewater disposal system is not anticipating a disposal system with a capacity of 2,000 gallons per day (GPD).

§120-812K – Water Quality Protection

- The applicant states development will help protect Windham’s water quality by using a public water system, a state-approved wastewater disposal system that shall comply with the State’s drink water standards, and stormwater management system to provide treatment to runoff. The day-to-day operations do not require substances that are hazardous, such as fuels, industrial chemicals, waste, etc.

§120-812L – Hazardous, Special and Radioactive Materials

- (1) No hazardous materials will be stored on site.

§120-812M – Shoreland Relationship

- The site is not in a shoreland zoning district.

§120-812N – Technical and Financial Capacity

- (1) The applicant has not provided an estimate of the project cost of development or financial capacity evidence. The applicant shall provide evidence of financial capacity for the *preliminary plan review*.
- (2) The applicant has hired DM Roma Consulting Engineers, for site planning, permitting, and engineering services for site development.

§120-812O – Solid Waste Management

- The applicant proposes that the two-family dwellings with participate in the Town’s curbside collection program.

§120-812P – Historical and Archaeological Resources

- The applicant shall provide for *preliminary plan review* evidence from the State showing that there are no historic or archaeological resources onsite.

§120-812Q – Floodplain Management

- The site is not located in the mapped FEMA 100–year floodplain hazard.

§120-812R – Exterior Lighting

- (1) The applicant will provide an acceptable lighting plan with hooded or shielded fixtures, cut sheets, and locations for review for the preliminary plan review.
- (2) The applicant shall connect all light poles and other exterior light fixtures underground.

§120-812S – Noise

- (1) The proposed condominium shall not exceed 55 dB between 7:00 AM to 10:00 PM and 45 dB between 10:01 PM to 6:59 AM.
- (3) No construction activities are allowed between the hours of 10:00 PM and 6:00 AM.

§120-812T – Storage of Materials and Screening (Landscape Plan)

- The applicant will provide a landscaping plan and planting schedule for *preliminary plan review*.

§120-814 Multifamily development standards.

A. Building Architecture. For the *final plan review*, the applicant shall provide building elevations for review.

- (1) Architectural variety
 - (a) The building has a variety of techniques to visually break up the façade, a varied roof lines, and some variation in window sizes.
- (2) Facade.
 - (a) The building horizontal articulations are provided throughout the building, and rooflines incorporate varying heights and ridgelines.
- (3) Orientation.
 - (a) The building entrances shall be oriented to face the street.

- Table 3, Table 4, and the applicable cross sections in Appendix B Street Standards.
- [2] Rights-of-way. The minimum right-of-way width for a "major private road" in Table 3 of Appendix B is not applicable to an access drive.
 - [3] Setbacks. There shall be no minimum setback required between an access drive and a structure.
 - (c) Curb cuts on the access drive must be separated by a minimum of 75 feet where possible and aligned with curb cuts on the opposite side of the access drive to the greatest extent possible.
 - (d) Access drives shall remain private and shall not be maintained or repaired by the Town. A note shall appear on the site plan: All internal access roads and driveways shall remain private and shall be maintained by the developer, lot owners, homeowners/condominium association, or road association and shall not be offered for acceptance, or maintained, by the Town of Windham unless they meet all municipal street design and construction standards at the time of offering.

§120-911 – SITE PLAN PERFORMANCE STANDARDS

§120-911A – Basic Subdivision layout

- (1) The property has 70,958 square feet (approximately 1.63 acres) exceeding the 40,000 square feet minimum lot size in the C-4 zoning district.
 - (a) The applicant provided a net residential density calculation; with 0 deductions, for the net area of 70,958 SF. The net residential density for C-4 is 5,000 SF, equaling 14 dwelling units.
 - (e) For the final plan review, the applicant shall consult with the E-911 Addressing Officer to assign lot numbers and a street name.
- (2) For the preliminary plan review, the applicant shall show where the proposed utilities will be located and shall be installed underground.
- (3) For the preliminary plan review, the applicant shall show the location of the proposed subdivision monuments.

§120-911B – Sufficient water; water supply.

- (3) For the preliminary plan review, the applicant shall show water line and hydrant locations. The applicant shall provide for *the preliminary plan review* a PWD letter or email stating the system has capacity to serve the new development. An ability to serve letter from PWD approving the design of the water service is required for final plan review.

§120-911C - Erosion Control and sedimentation control

- (1) For the preliminary plan review, the applicant shall provide a soil erosion and sediment control plan showing the use of erosion and sediment control best management practices (BMPs) at the construction site consistent with the minimum standards outlined in the Maine DEP Stormwater Rule Chapter 500 Appendix A – Erosion and Sediment Control, Appendix B – Inspections and Maintenance, Appendix C – Housekeeping. Erosion and Sedimentation Control. BMPs shall be designed, installed,

and maintained in accordance with the standards contained in the latest revisions of the following Maine DEP documents.

- (2) For the preliminary plan review, the developer shall provide a statement for the Maine licensed professional civil engineer preventing soil erosion and sedimentation from entering water bodies, wetlands, and adjacent properties.
- (3) For the preliminary plan review, the applicant or develop shall consider the topsoil as part of the subdivision is not to be removed from the site.
- (4) Except for normal thinning and landscaping, existing vegetation shall be left intact to prevent soil erosion. *The Board may require a developer to take measures to correct and prevent soil erosion in the proposed subdivision.*

§120-911D – Sewage disposal

- (2) The applicant is proposing a private sewage system for the development. The preliminary plan review, the applicant must submitted evidence of site suitability for subsurface sewage disposal prepared State of Maine Subsurface Waste Disposal Rules. The applicant shall provide evidence that the septic disposal field will mee the State’s drinking water standards.

§120-911E – Impact Natural Beauty, Aesthetics, Historic Sites, Wildlife Habit, Rare Natural Areas, or Public Access to the Shoreline

- (1) The applicant is developing access from Tandberg by creating the access driveway in the general location of the existing driveway.
 - (a) For preliminary plan review, the applicant shall provide a note not allowing the clearing of trees where tree cover is depicted on the plan for at least five years. Mandatory buffer for stormwater or other reasons shown on the plan shall not be cleared of vegetation unless the Planning Board grants an amendment to the subdivision or maintenance that does not alter the purpose for which the buffer was required.
 - (b) For preliminary plan review, the applicant must provide a landscape plan including a list of proposed plant species and their size at the time of installation and maturity, including the street tree plantings no more than 50 feet apart
- (2) For preliminary plan review, the applicant shall provide reservation or dedication and maintenance of open space, common land, facilities such as the stormwater management system, among others, and service in the form of homeowner’s association documentation.

§120-911F – Conformance with Land Use Ordinances

Comprehensive Plan:

- The plan does meet the goals of the 2024 Comprehensive Plan. The property is located in the Residential growth area.

Land Use Ordinance, Chapter 120 Article 9:

- There is a net residential density in the Commercial IV zoning district of 5,000 SF

Subdivision Ordinance, Chapter 120 Article 9:

- Standard notes, the standard conditions of approval, and approved waiver must be shown on the plans.
- For the final plan review, a digital transfer of the subdivision plan data must be submitted for inclusion with the Town's GIS.

Growth Management, [Chapter 101](#):

- Growth permits are required for the creation of each new dwelling structure. Growth permit applications are submitted with building permit applications.

§120-911G – Financial and Technical Capacity

- (1) See above in the site plan performance standards for review.
- (2) See above in the site plan performance standards for review.

§120-911H – Impact on Ground Water Quality or Quantity

- (1) For preliminary plan review, the applicant shall provide evidence that the subdivision shall not increase any contaminant concentration in the groundwater and shall meet the State's drinking water standards. A hydrogeological evaluation shall be required to demonstrate nitrates as nitrogen meet the maximum contaminant level.
- (2) For preliminary plan review, the applicant shall provide evidence the proposed will be connected to public water system.

§120-911I – Floodplain Management

- The subject property is not within a mapped FEMA Floodplain boundary.

§120-911J – Stormwater

- See Site Plan Performance Standard above for details.
- The responsibility of maintaining the stormwater management system will be assigned to the owner, as per [§120-911N](#).
- For final plan review, applicants must submit any with covenants and restrictions associated with a stormwater maintenance and inspection plan.

§120-911K – Conservation Subdivision

- (1) The applicant is not proposing a conservation subdivision, therefore this section is not applicable.

§120-911L – Compliance with Timber Harvesting Rules

- The applicant stated the subdivision will not involve timber harvesting activity.

§120-911M – Traffic Conditions and Street

- For preliminary plan review, the applicant shall provide a traffic summary, if the proposed PM hour trips ends are below 50 vehicle trips.
- The applicant is proposing a hammerhead turn around at the end of the access driveway for vehicle and truck maneuvering

§120-911N – Maintenance of common elements.

- For the final plan review, the applicant shall provide information on maintenance of common elements.

(SITE PLAN) CONCLUSIONS (*final plan review*)

1. ~~The plan for development **reflects/does not reflect** the natural capacities of the site to support development.~~
1. ~~Buildings, lots, and support facilities **will/will not** be clustered in those portions of the site that have the most suitable conditions for development.~~
2. ~~Environmentally sensitive areas, including but not limited to, wetlands; steep slopes; flood plains; significant wildlife habitats, fisheries, and scenic areas; habitat for rare and endangered plants and animals; unique natural communities and natural areas; and sand and gravel aquifers **will/will not** be maintained and protected to the maximum extent.~~
3. ~~The proposed site plan **has/does not have** sufficient water available for the reasonably foreseeable needs of the site plan.~~
4. ~~The proposed site plan **will/will not** cause unreasonable soil erosion or a reduction in the land's capacity to hold water so that a dangerous or unhealthy condition results.~~
5. ~~The proposed use and layout **will/will not** be of such a nature that it will make vehicular or pedestrian traffic no more hazardous than is normal for the area involved.~~
6. ~~The proposed site plan **will/will not** provide adequate sewage waste disposal.~~
7. ~~The proposed site plan **conforms/does not conform** to a duly adopted site plan regulation or ordinance, comprehensive plan, development plan, or land use plan.~~
8. ~~The developer **has/does not have** the adequate financial capacity to meet the standards of this section.~~
9. ~~The proposed site plan **will/will not** alone or in conjunction with existing activities, adversely affect the quality or quantity of groundwater.~~
10. ~~The proposed site plan **will/will not** provide for adequate stormwater management.~~
11. ~~The proposed location and height of buildings or structure walls and fences, parking, loading, and landscaping shall be such that it **will/will not** interfere with or discourage the appropriate development in the use of land adjacent to the proposed site or unreasonably affect its value.~~
12. ~~On site landscaping **does/does not** provide adequate protection to neighboring properties from detrimental features of the development that could be avoided by adequate landscaping.~~
13. ~~All freshwater wetlands within the proposed subdivision **have/have not** been identified on the plan.~~
14. ~~Any river, stream, or brook within or abutting the subdivision **has/has not** been identified on any maps submitted as part of the application.~~
15. ~~If any lots in the proposed subdivision have shore frontage on a river, stream, brook, or great pond as these features are defined in Title 38, section 480-B, none of the lots created within the subdivision **has/do have** a lot of depth to shore frontage ratio greater than 5 to 1.~~
16. ~~The long term cumulative effects of the proposed site plan **will/will not** unreasonably increase a great pond's phosphorus concentration during the construction phase and life of the proposed subdivision.~~

17. ~~For any proposed subdivision that crosses municipal boundaries, the proposed subdivision~~ **will/will not** ~~cause unreasonable traffic congestion or unsafe conditions with respect to the use of existing public ways in an adjoining municipality in which part of the subdivision is located.~~
18. ~~The timber on the parcel being subdivided~~ **has/has not** ~~been harvested in violation of rules adopted pursuant to Title 12, section 8869, subsection 14.~~

(SUBDIVISION) CONCLUSIONS *(For preliminary plan review)*

1. ~~The development plan~~ **reflects/does not reflect** ~~the natural capacities of the site to support development.~~
2. ~~Buildings, lots, and support facilities~~ **will/will not** ~~be clustered in those portions of the site that have the most suitable conditions for development.~~
3. ~~Environmentally sensitive areas, including but not limited to wetlands; steep slopes; flood plains; significant wildlife habitats, fisheries, and scenic areas; habitat for rare and endangered plants and animals; unique natural communities and natural areas; and sand and gravel aquifers~~ **will/will not** ~~be maintained and protected to the maximum extent.~~
4. ~~The proposed subdivision~~ **has/does not have** ~~sufficient water available for the reasonably foreseeable needs of the site plan.~~
5. ~~The proposed subdivision~~ **will/will not** ~~cause unreasonable soil erosion or a reduction in the land's capacity to hold water so that a dangerous or unhealthy condition results.~~
6. ~~The proposed use and layout~~ **will/will not** ~~be of such a nature that it will make vehicular or pedestrian traffic no more hazardous than is normal for the area involved.~~
7. ~~The proposed subdivision~~ **will/will not** ~~provide adequate sewage waste disposal.~~
8. ~~The proposed subdivision~~ **conforms/does not conform** ~~to a duly adopted subdivision regulation or ordinance, comprehensive plan, development plan, or land use plan.~~
9. ~~The developer~~ **has/does not have** ~~the adequate financial capacity to meet the standards of this section.~~
10. ~~The proposed subdivision~~ **will/will not** ~~alone or in conjunction with existing activities, adversely affect the quality or quantity of groundwater.~~
11. ~~The proposed subdivision~~ **will/will not** ~~provide for adequate stormwater management.~~
12. ~~The proposed location and height of buildings or structure walls and fences, parking, loading, and landscaping shall be such that it~~ **will/will not** ~~interfere or discourage the appropriate development in the use of land adjacent to the proposed site or unreasonable affect its value.~~
13. ~~On-site landscaping~~ **does/does not** ~~provide adequate protection to neighboring properties from detrimental features of the development that could be avoided by adequate landscaping.~~
14. ~~All freshwater wetlands within the proposed subdivision~~ **have/have not** ~~been identified on the plan.~~
15. ~~Any river, stream, or brook within or abutting the subdivision~~ **has/has not** ~~been identified on any maps submitted as part of the application.~~
16. ~~The proposed subdivision~~ **will/will not** ~~provide for adequate stormwater management.~~

- ~~17. If any lots in the proposed subdivision have shore frontage on a river, stream, brook, or great pond as these features are defined in [Title 38, §480-B](#), none of the lots created within the subdivision **has/does not have** a lot depth to shore frontage ratio greater than 5 to 1.~~
- ~~18. The long term cumulative effects of the proposed subdivision **will/will not** unreasonably increase a great pond's phosphorus concentration during the construction phase and life of the proposed subdivision.~~
- ~~19. For any proposed subdivision that crosses municipal boundaries, the proposed subdivision **will/will not** cause unreasonable traffic congestion or unsafe conditions with respect to the use of existing public ways in an adjoining municipality in which part of the subdivision is located.~~
- ~~20. The timber on the parcel being subdivided **has/has not** been harvested in violation of rules adopted pursuant to [Title 12, §8869, sub§14](#).~~

CONDITIONS OF APPROVAL (MAJOR SITE PLAN)

1. Approval is dependent upon and limited to the proposals and plans contained in the application dated June 23, 2025 as amended TBD and supporting documents and oral representations submitted and affirmed by the applicant, and conditions, if any, imposed by the Planning Board. Any variation from such plans, proposals, supporting documents, and representations is subject to review and approval by the Planning Board or the Town Planner in accordance with [§120-815](#) of the Land Use Ordinance.
2. In accordance with [§120-815C\(1\)\(b\)](#) of the Land Use Ordinance, the Construction of improvements covered by any site plan approval shall be completed within two years of the date upon which the performance guarantee is accepted by the Town Manager. If construction has not been completed within the specified period, the Town shall, at the Town Manager's discretion, use the performance guarantee to either reclaim and stabilize the site or to complete the improvements as shown on the approved plan.

CONDITIONS OF APPROVAL (MAJOR SUBDIVISION)

1. Approval is dependent upon and limited to the proposals and plans contained in the application dated June 23, 2025 as amended [*the date of the final plan approval*] and supporting documents and oral representations submitted and affirmed by the applicant, and conditions, if any, imposed by the Planning Board. Any variation from such plans, proposals, supporting documents, and representations is subject to review and approval by the Planning Board or the Town Planner in accordance with [§120-912](#) of the Land Use Ordinance.
2. In accordance with [§120-911N\(5\)](#) of the Land Use Ordinance, the condominium association documents shall be recorded in the Cumberland County Registry of Deeds within 90 days of the date that the subdivision plan is recorded in the Cumberland County Registry of Deeds. Evidence of such recording shall be provided to the Planning Department. No units shall be sold in the subdivision prior to recording and all deeds shall reference the declaration establishing the condominium association.

3. The development is subject to the following [Article 12 Impact Fees](#), to be paid with the issuance of new building permits for the expanded uses: [North Route 302 Road Improvements Impact Fee](#) of **TBD** (*TBD during final plan review per peak hour trip through Route 302/Anglers Rd/Whites Bridge Intersection*); [Recreation Impact Fee](#), [Open Space Impact Fee](#), [Public Safety Impact Fee](#); and [Municipal Office Impact Fee](#). All fees will be determined and collected for any building, or any other permit for the development, [§120-1201C](#).
4. In accordance with [§120-914B\(5\)](#) of the Land Use Ordinance, the Construction of improvements covered by any subdivision plan approval shall be completed within two years of the date upon which the performance guarantee is accepted by the Town Manager. The developer may request a one-year extension of the construction completion deadline prior to the expiration of the period. Such request shall be in writing and shall be made to the Planner. The Town Manager may require an update to the schedule of values and the amount of the guarantee when accepting an extension of the construction period. If construction has not been completed within the specified period, the Town shall, at the Town Manger's discretion, use the performance guarantee to either reclaim and stabilize or to complete the improvements as shown on the approved plan.