

## Jasmine Lopez

---

**From:** Stephen J. Puleo  
**Sent:** Tuesday, July 9, 2024 4:26 PM  
**To:** Jasmine Lopez  
**Subject:** FW: 322 Roosevelt Trail

---

**From:** John K. Wescott <jkwescott@windhammaine.us>  
**Sent:** Tuesday, July 9, 2024 4:24 PM  
**To:** Stephen J. Puleo <sjpuleo@windhammaine.us>  
**Cc:** Brent J. Libby <bjlibby@windhammaine.us>  
**Subject:** 322 Roosevelt Trail

Good afternoon, Steve,

After looking at the proposed addition to the building at 322 Roosevelt trail the sprinkler system would need to be updated to include sprinkler heads in the sleeping spaces. Also, smoke / carbon monoxide detectors in the sleeping spaces.

Respectfully,

John K.Wescott  
Deputy Fire Chief  
Inspections, Prevention, Operations  
CPE-I, CFI-I