

Stephen J. Puleo

From: Brent J. Libby
Sent: Monday, November 8, 2021 3:48 PM
To: dustin@dmroma.com; Stephen J. Puleo
Subject: RE: Turn movement response for Androscoggin Street

That should cover it, for safety sake and enforcement down the road it would probably be wise to label it a fire lane.

Thanks!!

Brent J. Libby, Chief
Windham Fire-Rescue
375 Gray Road
Windham, Maine 04062
207-892-1911 x2
bjlibby@windhammaine.us

From: dustin@dmroma.com <dustin@dmroma.com>
Sent: Monday, November 8, 2021 3:44 PM
To: Stephen J. Puleo <sjpuleo@windhammaine.us>
Cc: Brent J. Libby <bjlibby@windhammaine.us>
Subject: RE: Turn movement response for Androscoggin Street

Attached is a plan showing a proposed 15-ft wide easement to be granted to the Town of Windham. This easement area would be paved, and any parking would need to be located outside of this easement area.

Dustin M. Roma, P.E.



PO Box 1116, Windham, ME 04062
P: (207) 310-0506

From: Stephen J. Puleo <sjpuleo@windhammaine.us>
Sent: Monday, November 8, 2021 3:31 PM
To: dustin@dmroma.com
Cc: Brent J. Libby <bjlibby@windhammaine.us>
Subject: RE: Turn movement response for Androscoggin Street

We would need an access easement either way. What do you think Chief?

Steve

From: dustin@dmroma.com <dustin@dmroma.com>
Sent: Monday, November 8, 2021 3:28 PM
To: Stephen J. Puleo <sjpuleo@windhammaine.us>

Cc: Brent J. Libby <bjlibby@windhammaine.us>

Subject: RE: Turn movement response for Androscoggin Street

What if we pushed the parking spaces 10 ft further back off the road? I know it's not ideal but it would be an improvement over what is there now.

Dustin M. Roma, P.E.



PO Box 1116, Windham, ME 04062

P: (207) 310-0506

From: Stephen J. Puleo <sjpuleo@windhammaine.us>

Sent: Monday, November 8, 2021 2:39 PM

To: dustin@dmroma.com

Subject: Turn movement response for Androscoggin Street

See the Chief response below.

Thanks,
Steve

From: Brent J. Libby <bjlibby@windhammaine.us>

Sent: Monday, November 8, 2021 2:18 PM

To: Stephen J. Puleo <sjpuleo@windhammaine.us>

Subject: RE: Androscoggin Street

That would not work for us, especially taking into account any snowbanks.

Brent J. Libby, Chief
Windham Fire-Rescue
375 Gray Road
Windham, Maine 04062
207-892-1911 x2
bjlibby@windhammaine.us