

CONSOLIDATED

APPLICATION FOR POLE LOCATIONS

August 2, 2019

To the Board of Councilors
of Windham, Maine

CONSOLIDATED COMMUNICATIONS OF NORTHERN NEW ENGLAND COMPANY, LLC and **CENTRAL MAINE POWER COMPANY** respectfully request(s) permission for a location for poles and cables and wires thereon, including the necessary sustaining, supporting and protecting fixtures in, along, upon and across the following named public streets and highways:


IN THE TOWN OF WINDHAM, MAINE

Chute Road – Placement of new Pole 37 ½ [018H] approximately 725 feet Southeasterly of the intersection with center line of Falcon Road, one pole


THIS APPLICATION IS BEING SUBMITTED WITHOUT PUBLIC NOTICE BY PUBLICATION

Said poles to be erected substantially in accordance with the plan filed herewith marked Consolidated No. 332327 dated July 24, 2019 and shall be of wood or other suitable material, and the cables and wires shall be run at the height in compliance with standards of the National Electrical Safety Code at highway crossings and elsewhere for electric cables and wires, and (or) for telephone cables and wires. All cables and wires to be maintained in accordance with standards of the National Electrical Safety Code.

CONSOLIDATED COMMUNICATIONS OF
NORTHERN NEW ENGLAND COMPANY LLC

By 
Jessica Theriault
Right of Way

CENTRAL MAINE POWER COMPANY

By 
Herb Stevens
Supervisor – Integrated Field Design

PERMIT FOR POLE LOCATIONS

To the Board of Councilors
Windham, Maine

ORDERED: That **CONSOLIDATED COMMUNICATION OF NORTHERN NEW ENGLAND COMPANY LLC** and **CENTRAL MAINE POWER COMPANY** be and is/are hereby authorized and permitted to erect and maintain poles and cables and wires to be placed thereon, together with such sustaining, supporting and protecting fixtures as said companies may deem requisite, in, along, upon and across the public streets and highways of said Town of Windham as hereinafter designated, as requested in application of said companies dated the 2nd day of August, 2019.

All construction under this permit shall be in accordance with the following specifications: The poles shall be located between the vehicular traveled section of the way and the limits of the highway, shall be set firmly in the ground, substantially at locations indicated upon the plan marked Consolidated No. 332327 dated July 24, 2019 filed with said application, and shall be of wood or other suitable material, and the cables and wires shall be run at the height in compliance with standards of the National Electrical Safety Code at highway crossings and elsewhere for electric cables and wires, and (or) for telephone cables and wires.

All cables and wires to be maintained in accordance with standards of the National Electrical Safety Code.

Following are the public streets and highways above referred to:

Chute Road – Placement of new Pole 37 1/2 [018H] approximately 725 feet Southeasterly of the intersection with center line of Falcon Road, one pole

THIS PERMIT IS BEING GRANTED WITHOUT PUBLIC NOTICE BY PUBLICATION

It is further adjudged and voted that satisfactory proof of validity of the applicant's notice or procedures required by statute has been given upon the application of said companies to erect poles with the cables and wires thereon in, along, upon and across the public streets and highways of Windham, Maine, designated by this permit.

Board of Councilors

1. _____

4. _____

2. _____

5. _____

3. _____

6. _____

PERMIT GRANTED

8-13, 2019

7. _____

This permit is recorded in the Records of the Town Clerk of Windham,
Book , Page

Town Clerk

FAIRPOINT NO. 332327 MUNICIPALITY WINDHAM, ME DATE 7/24/2019
PLAN FOR PROPOSED POLE LOCATION FOR NEW SERVICESCMP EON# 801000244684
TEL MEMO # 19-MEI-101877

CHUTE RD TEL RT 606

EOP _____

C_L _____

EDGE OF PAVEMENT _____

22'

P.37-1/2
GPS: 43.745707, -70.409880



P.37-1/2
P.37
[018H]

P.38
[019]

725' TO FALCON RD

**TEL TO PLACE NEW MID-SPAN POLE 37-1/2 40FT CL 4 SPP FOR
NEW ELCO POWER SERVICES.**

ALL PLANT IS LOCATED WITHIN HIGHWAY LIMITS

NO SCALE

DOT NO.

NO.

PREPARED BY

PATRICK MORRISON

CHECKED BY

PUBLISH

NON-PUBLISH

PERMIT BY RULE

STATUTORY PROCEDURE

LEGEND

- = POLE LOCATION
- = PEDIESTAL POST LOCATION
- ⊗ = POLE LOCATION - JOINED WITH CMP
- ⊗ = POLE LOCATION - JOINED WITH POLE
- ⊗ = CENTER LINE
- EOP = EDGE OF PAVEMENT
- POWER CO. = VOLTS PHASE
- TEL. CO. = AERIAL FIBER OPTIC CABLE
- [XX] = CMP POLE NUMBER

DISTANCES SHOWN ARE APPROXIMATE AND ALL SPANS MEASURED ALONG APPLICANT'S CONSTRUCTION CENTERLINE



