

## Jasmine Lopez

---

**From:** Stephen J. Puleo  
**Sent:** Tuesday, July 2, 2024 1:14 PM  
**To:** Jasmine Lopez  
**Subject:** FW: Cross Ridge Subdivision

As promised...

*Have an amazing day!*

**Best regards,**



**Office:** [207-894-5960](tel:207-894-5960) x6123 ▪ **Direct:** [207-777-1927](tel:207-777-1927)

**Mobile:** [207-712-1069](tel:207-712-1069) ▪ **Fax:** [207-892-1916](tel:207-892-1916)

**NOTICE:** Under Maine's Freedom of Access ("Right to Know") law, documents – including emails – in the possession of public officials about town business are considered public records. This means if anyone asks to see it, we are required to provide it. There are very few exceptions. We welcome citizen comments and want to hear from our constituents, but please keep in mind that what you write in an email is not private and will be made available to any interested party.

**PUBLIC HOURS:** **Monday 7:00-5:00; Tuesday 7:00-6:00;**  
**Wednesday 7:00-5:00; Thursday 7:00-4:00; Friday Closed**

---

**From:** John K. Wescott <jkwescott@windhammaine.us>  
**Sent:** Tuesday, June 25, 2024 10:43 AM  
**To:** Stephen J. Puleo <sjpuleo@windhammaine.us>  
**Cc:** Brent J. Libby <bjlibby@windhammaine.us>  
**Subject:** Cross Ridge Subdivision

Good morning, Steve,

The fire rescue department are all set with the Cross Ridge Subdivision as proposed. However, we are requesting that each cistern to be installed to the NFPA 22 Standard. Also, our hard suction are 6" not 4.5" as listed, so the adapter needs to be 6" on the suction pipe. And, we will need a 2.5" recirculation pipe added to the tank as well as a water level gauge indicator. The gauge must be visible from a vehicle or fire apparatus.

Respectfully,

John K.Wescott  
Deputy Fire Chief  
Inspections, Prevention, Operations  
CPE-I, CFI-I