

FAIRPOINT

APPLICATION FOR POLE LOCATIONS

August 13, 2014

To the Board of Councilors
of Windham, Maine

NORTHERN NEW ENGLAND TELEPHONE OPERATIONS LLC and
CENTRAL MAINE POWER COMPANY respectfully request permission for a location
for poles and cables and wires thereon, including the necessary sustaining, supporting and
protecting fixtures in, along, upon and across the following named public streets and
highways:


IN THE TOWN OF WINDHAM, MAINE

**Collinwood Circle – Placement of Pole ½ [H] from approximately 130' Southwesterly of
Running Brook Rd, one pole**


THIS APPLICATION IS BEING SUBMITTED WITHOUT PUBLIC NOTICE BY PUBLICATION

Said poles to be erected substantially in accordance with the plan filed herewith
marked FairPoint No. **279736**, dated July 22, 2014 and shall be of wood or other suitable
material, and the cables and wires shall be run at the height of not less than 18 feet from
the ground at highway crossings and not less than 15 feet from the ground elsewhere for
electric cables and wires, and (or) not less than 8 feet elsewhere for telephone cables and
wires. All cables and wires to be maintained in accordance with standards of the
National Safety Code.

**NORTHERN NEW ENGLAND TELEPHONE
OPERATIONS LLC**

By 
Deborah Murphy
Specialist - Engineer & Right of Way

CENTRAL MAINE POWER COMPANY

By 
Julie Paul
Pole Permit Administrator

PERMIT FOR POLE LOCATIONS

**To the Board of Councilors
Windham, Maine**

ORDERED: That **NORTHERN NEW ENGLAND TELEPHONE OPERATIONS, LLC** and **CENTRAL MAINE POWER COMPANY** be and are hereby authorized and permitted to erect and maintain poles and cables and wires to be placed thereon, together with such sustaining, supporting and protecting fixtures as said companies may deem requisite, in, along, upon and across the public streets and highways of said Town of Windham as hereinafter designated, as requested in application of said companies dated the 13th day of August, 2014.

All construction under this permit shall be in accordance with the following specifications:
The poles shall be located between the vehicular traveled section of the way and the limits of the highway shall be set firmly in the ground, substantially at locations indicated upon the plan marked FairPoint No. 279736 dated July 22, 2014 filed with said application, and shall be of wood or other suitable material, and the cables and wires shall be run at the height of not less than 18 feet from the ground at highway crossings and not less than 15 feet from the ground elsewhere for electric cables and wires and-or not less than 8 feet elsewhere for telephone cables and wires.

All cables and wires to be maintained in accordance with standards of the National Electrical Safety Code.

Following are the public streets and highways above referred to:

**Collinwood Circle – Placement of Pole ½ [H] from approximately 130' Southwesterly of Running Brook Rd,
one pole**

THIS PERMIT IS BEING GRANTED WITHOUT PUBLIC NOTICE BY PUBLICATION

It is further adjudged and voted that satisfactory proof of validity of the applicant's notice or procedures required by statute has been given upon the application of said companies to erect poles with the cables and wires thereon in, along, upon and across the public streets and highways of Windham, Maine, designated by this permit.

Board of Councilors


PERMIT GRANTED

_____, 2014

This permit is recorded in the Records of the _____ of _____,
Book _____, Page _____.

Town Clerk

Fairpoint Comm 279736 MUNICIPALITY Windham date 2014
 PLAN FOR Collinwood Cir P 1/2



LEGEND

- = POLE LOCATION
- = POLE LOCATION-JOINT WITH _____
- = _____ POLE
- = CENTER LINE
- = PEDISTAL POST LOCATION
- = WARNING SIGN LOCATION
- = MANHOLE LOCATION
- = BURIED CABLE/CONDUIT LOCATION

INITIAL PROPOSED FACILITIES TO BE:

POWER CO. = 7200 VOLTS Single PHASE. TEL. CO. =

NO SCALE


DOT NO. _____
 NO. _____
 PREPARED BY HG Loring
 CHECKED BY _____
 PUBLISH _____
 NON-PUBLISH _____

DISTANCES SHOWN ARE APPROXIMATE AND ALL SPANS MEASURED ALONG APPLICANT'S CONSTRUCTION CENTERLINE

PERMIT BY RULE
 STATUTORY PROCEDURE



Address Running Brook Rd
Windham, ME 04062



©2014 Google