

From: Anderson, Dwight <Dwight.Anderson@stantec.com>
Sent: Tuesday, May 29, 2018 4:28 PM
To: Jonathan R. Earle; Amanda L. Lessard
Cc: bhansen@rsu14.org
Subject: RE: 18-15 - RSU 14 Gravel Parking Lot Comments
Attachments: 2011-08-12-Woodruff-DEP Minor Amendment.pdf; Minor Amendment Permit Signed.pdf

Jon,

Attached is the MeDEP permit addressing comment #1 and water quality calculations near the end of the 8M file addressing comment #3 (Figure 6 shows graphically). I will respond to comment #2 tomorrow.

Sincerely,

Dwight Anderson, PE

Project Manager

Direct: (207) 887-3438

Fax: (207) 879-0896

Stantec Consulting Services Inc.
482 Payne Road Scarborough Court
Scarborough ME 04074-8929 US



The content of this email is the confidential property of Stantec and should not be copied, modified, retransmitted, or used for any purpose except with Stantec's written authorization. If you are not the intended recipient, please delete all copies and notify us immediately.

From: Jonathan R. Earle <jrearle@windhammaine.us>
Sent: Tuesday, May 29, 2018 4:15 PM
To: Amanda L. Lessard <allessard@windhammaine.us>; Anderson, Dwight <Dwight.Anderson@stantec.com>
Cc: bhansen@rsu14.org
Subject: 18-15 - RSU 14 Gravel Parking Lot Comments

To all,

Below are my comments regarding the RSU 14 gravel parking lot project. Please let me know if you have any questions.

1. Will you be providing us a copy of the DEP permit that address stormwater quantity and quality for the parking expansion?
2. Provide a maintenance plan for the underdrained soil filter.
3. The paved connection from the existing parking lot to the proposed gravel lot appears to drain away from the soil filter. Is this additional runoff addressed in DEP permit both for quality and quantity?

Jon

Jon Earle, PE

Town Engineer
Town of Windham

Office: (207) 894-5900, ext. 6124

Cell: (207) 212-1802

www.windhammaine.us