

## Stephen J. Puleo

---

**From:** John K. Wescott  
**Sent:** Tuesday, March 19, 2024 9:16 AM  
**To:** Stephen J. Puleo  
**Subject:** 868 Roosevelt Trail.

Good morning, Steve,

I only have a couple of things on the sketch plan. I'm ok with one way drive to the rear of the building. However, the proposed parking spots next to the garage may be problematic for people exiting the building in an emergency. Just move those parking spaces so they wouldn't cause confusion with the exits and also put up a sign that says no parking fire lane. We wouldn't necessarily need another lock box for the gate but rather add a key to the new existing box on the front of the building. Hope this helps.

Respectfully,

John K.Wescott  
Deputy Fire Chief  
Inspections, Prevention, Operations  
CPE-I, CFI-I