

From: William Haskell <WHaskell@gorrillpalmer.com>
Sent: Monday, August 29, 2016 7:30 AM
To: Amanda L. Lessard; Lisa Fisher; 'Dustin Roma'
Subject: 2786.31 Abby Commons - Final Peer Review

Hi Amanda,

We received the following by email on 8/25/16:

- Final Subdivision Application Packet, dated 8/22/16, prepared by DM Roma Consulting Engineers.
- Plan Set with 9 drawings, dated 8/22/16, prepared by DM Roma Consulting Engineers.

We have reviewed the final application for conformance with the Town's Ordinances and general engineering standards and offer the following comments:

1. Applicant should submit the final DEP approved stormwater maintenance plan, if revisions were required by MaineDEP.
2. The Town should note that DEP and DHS permits require that the Applicant retain the Design Engineer to oversee the construction of the stormwater infiltration basins and the engineered septic system.

Thank you,

William C. Haskell | Principal



707 Sable Oaks Drive, Suite 30 | South Portland, ME 04106
207.772.2515 (office) | 207.318.7052 (mobile)
www.gorrillpalmer.com

The information transmitted is intended only for the person or entity to which it is addressed and may contain confidential and/or privileged material. Any review, retransmission, dissemination or other use of, or taking of any action in reliance upon, this information by persons or entities other than the intended recipient is prohibited. If you have received this email in error, please contact the sender and delete the material from any computer.