

Town of Windham Fire Prevention Code

Chapter 95



Submitted by the
Windham Fire-Rescue Department
in cooperation with the
Planning and Code Enforcement Departments

Adopted by Order 10-022, February 9, 2010; effective date March 11, 2010

Table of Contents

Article 01.1 Preface.....	3
Article 01.2 Definitions	5
Article 01.3 Fire Alarm Code.....	7
Article 01.4 Fire Suppression Code.....	9
Article 01.5 Plan Approval Ordinance.....	12
Article 01.6 Key Box Ordinance	13
Article 01.7 Open Burning Ordinance	14
Article 01.8 Occupancy Inspection Ordinance.....	16
Article 01.9 Water Supplies For Fire Fighting.....	17
Article 01.10 Appeal Process.....	18
Appendix A BOCA Code (1999 edition) Chapter 3, “Use or Occupancy”	
Appendix B Use Groups Quick Reference Guide	
Appendix C Areas Where Open Burning is Prohibited	

Article 01.1 Preface

It is the mission of the Windham Fire-Rescue Department, in combination with the Planning Department and Code Enforcement Department, to provide the safest, most reliable means of fire protection in the event of an emergency to all residents and visitors of our community. The people that live, work, and vacation within the town boundaries of Windham expect and deserve the highest level of safety and protection possible.

It is also the mission of the Windham Fire-Rescue Department to decrease the risk of fire in new commercial buildings and structures, and residential dwellings. It is our intent to prevent loss of life, and damage to property and the environment due to the effects of fire for the benefit of all in Windham including emergency responders.

A major component of providing this service is this fire prevention code, which is intended to reduce the risk of injury, loss of life, and damage to property due to fire situations, and provide life safety to occupants of buildings in Windham. In order to encompass the range of possible situations, this code makes use of nationally recognized codes such as BOCA (Building Officials Code Administrators) National Building Code (1999 edition), NFPA (National Fire Protection Association) Standards 13, 13D, 13R, and 72 as well as local ordinances together to meet the needs of the community.

This code is intended specifically to apply to BOCA Use Groups A-1, A-2, A-3, A-4, and A-5; Group B; Group E; Groups F-1 and F-2; Groups H-1, H-2, H-3, and H-4; Groups I-1, I-2, and I-3; Group M; Groups R-1 and R-2; and Groups S-1 and S-2 as defined in the BOCA building code (1999 Edition) Chapter 3, "Use Groups," a copy of which is attached at Appendix A of this Code. A "quick reference guide" summarizing occupancies and uses under BOCA Use Groups is attached at Appendix B. These occupancies are located throughout the town; consequently, this code shall apply to the entire town.

The Windham Fire-Rescue Department is charged with enforcing this codes for those occupancies and uses listed above. Except as otherwise provided, this code shall not be applied to buildings, structures, dwellings, uses, or occupancies in existence at the time of this code's adoption by the town.

It is the intent of this code to review all road accesses, in subdivisions and site plans. It is also the intent to review fire prevention measures, and general layout of all developments or dwellings, boarding houses, dormitories, hotels, motels, multiple-family dwelling, multiple single-family dwelling (complexes such as, garden style apartments, town houses, condominiums, and any dwelling that meets the definition as a dwelling that houses three (3) or more units with in one building).

The Windham Fire-Rescue Department is responsible for reviewing all required site plans and sprinkler plans; however, all sprinkler system plans shall still be subject to approval by the State Fire Marshal's Office. Due to the complexity of certain projects, buildings, or developments it may be necessary to require third party review of the plans prior to approval. Costs associated

with third party review shall be the sole responsibility of the applicant, developer, or property owner.

As part of its mission to protect public health, safety, life, and property the Windham Fire-Rescue Department, in cooperation with the Planning Department and Code Enforcement Department, is charged with enforcement of this code pursuant to the laws of the State of Maine.

Article 01.2 Definitions

Wherever used in this code the following terms used in this code shall have the meaning as given below.

Section 01.2.01 Authority Having Jurisdiction

The Authority Having Jurisdiction (AHJ) shall be the Chief of the Windham Fire-Rescue Department or his/her designee.

Section 01.2.02 Building

Any structure used or intended for supporting or sheltering any use or occupancy as defined by the building code adopted by the town.

Section 01.2.03 Building Officials Code Administrators (BOCA) Code

Commonly known as the BOCA National Building Code, the 1999 edition of this code or any successor code adopted by the Town Council shall be the reference for all new construction under this code.

Section 01.2.04 Classification Use Groups

Classification use groups shall refer to those listed in Chapter 3, "Use or Occupancy," of the BOCA Code, attached at Appendix A of this code.

Section 01.2.05 Dwelling

All structures in which sleeping accommodations are provided, including residential care facilities, but excluding those that are classified as institutional occupancies, shall be defined as dwellings classified under BOCA Use Group R-1 or R-2.

Section 01.2.06 Fire Wall

A wall separating buildings or subdividing a building to prevent the spread of fire and having a fire resistance rating and structural stability as defined by National Fire Protection Association (NFPA) Standard 221, section 3.3.14.6.

Section 01.2.07 Height

Height shall be as defined by the building code adopted by the town.

Section 01.2.08 National Fire Protection Association (NFPA)

The National Fire Protection Association (NFPA) develops, publishes, and disseminates codes and standards intended to minimize the possibility and effects of fire and other risks.

Section 01.2.09 Occupancy

The purpose for which a building or portion thereof is used or intended to be used.

Section 01.2.10 Recreational Fire

An outdoor fire burning materials other than rubbish, trash, or other waste materials where the fuel being burned is not contained in an incinerator, outdoor fireplace or barbeque pit and has a total fuel area of 3 feet or less in diameter or 2 feet less in height for pleasure, recreating, cooking, warmth, or similar purposes.

Section 01.2.11 Seasonal Dwelling

A detached dwelling unit, which is not the primary residence of the owner or occupant and/or is occupied only on a part time or seasonal basis, such as hunting or summer camp. This definition shall include, but not limited to: a dwelling which lacks one or more of the basic amenities, services, or utilities required for year-round or all weather occupancy, included but not limited to a winterized plumbing system, insulated walls and roof, heating source, or adequate water or waste water disposal systems.

Section 01.2.12 Sprinkler System

Shall mean any mechanical system that distributes water throughout a structure with the intent to extinguish or control fire.

Article 01.3 Alarm System Code

This article establishes requirements for alarm system installation and monitoring.

Section 01.3.01

All new building construction of 2,000 gross square feet of enclosed area or more classified as one of the following: BOCA Use Group A-1, A-2, A-3, A-4, or A-5; Group B; Group E; Group F-1 or F-2; Groups H-1, H-2, H-3, or H-4; Group I-1, I-2, or I-3; Group M; Group R-1 or R-2; or Group S-1 or S-2 shall be required to have an approved fully addressable fire alarm system that complies with NFPA 72 (2007 edition).

Section 01.3.02

NFPA 72 (2007 edition) shall be the standard used for all alarm systems installed under this code. Existing buildings of greater than 2,000 gross square feet of enclosed area without an alarm system as of the effective date of this ordinance shall not be required to install one, except as required by section 01.3.04 of this article.

Section 01.3.03

Any building that is required to have a sprinkler system shall have a supervised alarm, detection, and notification system that complies with NFPA 72 (2007 edition). This shall be considered a fully addressable system.

Section 01.3.04

In those instances where a proposed addition or additions brings the total combined building over 2,000 square feet the building shall have an approved alarm system that covers the whole occupancy, not only the new addition. Installation of the system in the existing portion(s) of the building may be phased, subject to the approval of the AHJ.

If said building is required under this section to have an alarm system, the alarm system shall be monitored.

Section 01.3.05

At no time shall anyone besides a certified technician or fire department representative deactivate or restore an alarm for any reason.

Section 01.3.06

In the event an alarm system installed under this Article malfunctions or is rendered inoperable, it must be repaired and returned to operation within thirty (30) calendar days. If the alarm system is not repaired within thirty (30) calendar days the occupancy may be subject to closure as further provided in this Article.

Section 01.3.07

With regard to this fire prevention code, the AHJ or his designee will have -authority in allowing occupancy of a building with a non-functioning alarm system. The AHJ may prohibit the continued occupancy of any structure or portion of a structure if it determines that such occupancy presents an immediate life-threatening situation. If the AHJ prohibits continued occupancy, no further occupancy shall occur until the situation identified as life threatening has been corrected in a manner that removes the threat and approved by the AHJ.

Section 01.3.08

Any occupancy with a non-functioning alarm system must be in communication with the Windham Fire – Rescue Department with details pertaining to getting the alarm fixed. If any such occupancy remains open without contacting the Windham Fire – Rescue Department after being informed of a non-functioning alarm system, and said occupancy is open past the 30-calendar day limit. Said occupancy is subject to closure if said occupancy remained open with knowledge of a non functional alarm system and failure to contact the local AHJ.

Section 01.3.09

The AHJ, with advice and consent of the Town Manager, is authorized to institute or cause to be instituted by the Town Council, in the name of the Town of Windham, any and all actions, legal or equitable, that may be appropriate or necessary for the enforcement of this article.

Section 01.3.10

The AHJ reserves the right to extend the 30 day reasonable time limit when and only when extenuating circumstances beyond the control of the occupant have been outlined and brought forth by the occupant before the 30 calendar days has expired. The AHJ and occupant must reach a date for correction to be completed by that satisfies both parties involved. This extension of time is intended to be used only for rare occasions and will not be granted for unsubstantiated reasons.

Section 01.3.11

This code shall apply to home occupations occupying 2,000 square feet or more in any one residential building or structure.

Section 01.3.12

All buildings, structures, or dwellings subject to this code may be inspected annually for fire alarm code and ordinance compliance.

Section 01.03.13

Violations of this code shall be enforced pursuant to 30-A M.R.S.A. §4452.

Article 01.4 Fire Suppression Code

This ordinance shall govern the installation and maintenance of sprinkler systems in buildings and structures subject to this code.

Section 01.4.01

All new buildings, structures, or dwellings of 2,000 gross square feet of enclosed area or more classified under one of the following Use Groups A-1, A-2, A-3, A-4, and A-5; Group B; Group E; Groups F-1 and F-2; Groups H-1, H-2, H-3, and H-4; Groups I-1, I-2, and I-3; Group M; Groups R-1 and R-2; and Groups S-1 and S-2 as defined in the BOCA building code (1999 Edition) Chapter 3, "Use Groups," a copy of which is attached at Appendix A of this code, shall be required to have an approved automatic fire sprinkler system in all areas of the building which must comply with this Article.

[Sprinkler systems for mixed use buildings are required by Section 519 of the Windham Land Use Ordinance, Chapter 140]

Section 01.4.02

An approved automatic sprinkler system shall mean a system installed in accordance with the National Fire Protection Association (NFPA) Standards 13, 13D, and 13R.

Section 01.4.03

All automatic sprinkler systems shall be an approved system listed by Underwriters Laboratories (UL) or Factory Mutual (FM) fire insurance underwriters, or otherwise deemed acceptable by the AHJ.

Section 01.4.04

Any structure requiring the installation of an NFPA Standard 13, 13D, or 13R System shall have a fire department connection. The location and type of fire department connection shall be approved by the AHJ. The fire department connection shall be identified by a sign, plaque, or plate identifying it as a "Fire Department Sprinkler Connection."

Section 01.4.05

The fire department connection shall be kept clear of any obstructions and maintained in good serviceable condition at all times.

Section 01.4.06

All systems to be installed shall be reviewed and approved by the AHJ in accordance with this ordinance.

Section 01.4.07

A permit shall be obtained from the Windham Fire-Rescue Department before the beginning of construction of any automatic fire sprinkler system required by this Article. A set of plans showing the entire sprinkler system and the rate of flow shall be provided at the time of permit application. A fee will be charged in an amount established by order of the Town Council. Upon completion of the sprinkler system, a set of "as-built" plans shall be provided, unless no changes were made to the system as permitted, prior to the issuance of a certificate of occupancy.

Section 01.4.08

A certificate of occupancy shall be issued only after the system has been properly installed and tested by a State of Maine licensed installer and approved by the AHJ.

Section 01.4.09

All sprinkler systems installed under this Article shall be required to comply with the following:

- A. Installation, extension, modification, or alteration shall be done by a State of Maine licensed installer.
- B. Plans for any system to be installed that contain ten (10) or more sprinkler heads, or the modification of an existing sprinkler system which includes ten (10) or more additional sprinkler heads, shall be approved by the State Fire Marshall's office and the AHJ.
- C. A tamper switch alarm at the system shut off.
- D. Any building that is required to be sprinkled by this code shall have an NFPA 72 compliant supervised alarm system installed. Referenced in Article 01.3 of this code.
- E. An outside water flow alarm.
- F. A Butterfly valve will not be allowed on any standard 13, 13D, or 13R systems.

Section 01.4.10

All sprinkler systems, standpipe systems, and all component parts shall be maintained in working condition at all times. It shall be unlawful to tamper with any system under this Article, except that this shall not prohibit necessary testing, repairs, alterations, or additions, provided that the testing, repairs, alterations or additions are done in such a way as to avoid the creation of a safety hazard. The AHJ shall be notified before such testing, repairs, alterations, or additions are conducted.

Automatic sprinklers and standpipes may be shut down subject to the following conditions:

- A. A letter stating that the sprinkler system and or standpipe have been shut down and rendered inoperable has been provided to the AHJ.
- B. The building remains unoccupied during the shutdown, except for the property owner or their representative to conduct occasional walk-through inspections.
- C. A licensed sprinkler contractor or inspector has properly shut down the sprinkler system.
- D. The system is reactivated only by an installer or technician licensed by the State of Maine.

Section 01.4.11

The AHJ may prohibit the continued occupancy of any structure or portion of a structure if it determines that such occupancy presents an immediate life-threatening situation. If the AHJ prohibits continued occupancy, no further occupancy shall occur until the situation identified as life threatening has been corrected in a manner that removes the threat and approved by the AHJ.

Section 01.4.12

Any building having more than one sprinkler riser shall have the risers separately zoned and wired to a local energy alarm panel to provide zone identification upon activation.

Section 01.4.13

The energy alarm panel shall be located as near as possible to the main exit door. There shall also be a building map located at the energy alarm panel showing each zone of the building.

Section 01.4.14

Any structure containing a sprinkler system shall be required to have a yearly test completed on the system by a qualified sprinkler technician. A written copy of the yearly test report shall be forwarded to the Fire Chief's office.

Section 01.4.15

A firewall in existing or new buildings shall not reduce the total area of the building or be considered a separate building. A firewall shall not be used as a starting or stopping point determining the gross area or square footage of the building nor shall a firewall designate the separation of buildings.

Section 01.4.16

Violations of this code shall be enforced pursuant to 30-A M.R.S.A. §4452.

Article 01.5 Plan Approval Ordinance

This article shall govern the plan approval process as it pertains to gaining approval from the Windham Fire-Rescue Department.

Section 01.5.01

Subdivision and site plans subject to Planning Board approval shall be reviewed by the AHJ; findings and recommendations by the Windham Fire-Rescue Department regarding the proposed plan's compliance with this code may be given to the applicant prior to the plans being presented to the planning board.

Section 01.5.02

The plan review by the Windham Fire-Rescue Department will have a fee that must be paid prior to the commencement of the AHJ's review. This fee will be assessed in an amount established by order of the Town Council.

Section 01.5.03

All residential dwellings including subdivisions, additions, buildings that are renovated, changed or altered within the Town of Windham shall be reviewed by the AHJ of the Windham Fire – Rescue Department for their compliance with this code. The Windham Fire Rescue Department will have ten (10) regular working days to evaluate the paperwork. The AHJ may recommend to the Planning Board that the developer to conform to specific fire protection or prevention measure as deemed necessary by the AHJ. This provision shall not apply to Use Groups R-3 and R-4.

Section 01.5.04

Violations of this code shall be enforced pursuant to 30-A M.R.S.A. §4452.

Article 01.6 Key Box Ordinance

This article established requirements for the installation of key boxes on new buildings for fire department access.

Section 01.6.01

Any newly constructed building subject to this code shall be required to install a key box for fire department access. This box shall be as approved by the fire department.

Sections: 01.6.02

A key or set of keys that allows entrance into an occupancy and access to all fire alarm and suppression systems shall be provided and placed in the box.

Section 01.6.03

Key boxes may be monitored by a security system.

Section 01.6.04

Key boxes shall meet requirements set by the AHJ.

Section 01.6.05

The AHJ must approve the location and style of box before installation.

Section 01.6.06

All installation procedures shall be followed to ensure the security of building keys prior to keys being placed in the box.

Section 01.6.07

Violations of this code shall be enforced pursuant to 30-A M.R.S.A. §4452.

Article 01.7 Open Burning Ordinance

This article establishes regulations for open burning. All open burning must comply with this article.

Section 01.7.01

A permit shall be required for all open burning, except as allowed under section 01.7.05.

Section 01.7.02

The AHJ shall have the authority to deny issuance of burning permits for the protection of public safety and health. A list of areas where open burning is prohibited is attached at Appendix C.

Section 01.7.03

At no time does the AHJ authority supersede the State of Maine Forest Service authority to ban burning. If the State of Maine deems burning is unsafe for the day or extended periods of time, it becomes the position of the AHJ automatically to deny permits for that time period. Local weather conditions permitting.

Section 01.7.04

Outdoor fireplaces shall not be located:

- Less than 25ft (7.6m) from any structure
- Within 25 ft (7.6m) of combustible materials, unless contained in an approved manner (UL or third party listed appliance)
- In any condition(s) that could cause a fire to spread to within 25 ft (7.6m) of a structure shall be eliminated prior to ignition.

Section 01.7.05

Open burning permits are not required for recreational fires, however if the fire creates a nuisance, health, or fire hazard the fire shall be extinguished upon order of the Windham Fire-Rescue Department, which shall have the authority to extinguish any fire if the property owner or other person responsible for the recreational fire fails to do so after such order.

Permanent barbecues, portable barbecues, outdoor fireplaces, grills or barrels shall not be used for disposal of trash, rubbish, or any other combustible waste material.

All fires shall be constantly attended by a competent adult and this person shall have a garden hose connected to a water supply, or other fire extinguishing equipment readily available for use.

Section 01.7.06

Violations of this code shall be enforced pursuant to 30-A M.R.S.A. §4452.

Special Note:

All open burning shall be in conformity to existing laws and regulations of the Maine Forest Service, Department of Environmental Protection and local municipal ordinances. In accordance with Title 12 statutes, the out-of-door burning of plastic, rubber, Styrofoam, metals, food wastes, chemicals, treated wood, or other solid wastes, except for wood wastes, is prohibited in all areas of the state of Maine.

Article 01.8 Occupancy Inspection Ordinance

This article shall establish requirements for approval from the AHJ prior to the issuance of certificates of occupancy.

Section 01.8.01

Any occupancy inspection that is conducted by the Town of Windham Code Enforcement Office on any occupancy that is required to conform to this code shall include the AHJ. The AHJ shall certify and make recommendation certifying that the building meets all conditions and regulations set forth by the Windham Fire-Rescue Department.

Section 01.8.02

If the occupancy under inspection does not conform to the requirements outlined during the plan approval process, the AHJ shall not approve the certificate of occupancy and shall make recommendations to the Code Enforcement Office for bringing the occupancy into compliance with the requirements of this code.

Section 01.8.03

All commercial buildings or dwellings that meet the requirements of this code may be inspected on a periodic basis for code and ordinance compliance for fire safety.

Article 01.9 Water Supplies For Fire Fighting

The following shall establish requirements for the operation and maintenance of fire hydrants.

Section 01.9.01

All fire hydrants, whether owned or leased by the town or privately owned, shall be maintained in proper operating condition at all times. Owners of private hydrants shall be responsible for all required maintenance including but not limited to, removing accumulations of snow/ice from the hydrant.

Section 01.9.02

Obstructions. No person or persons shall obstruct or permit to be obstructed by any means any fire hydrant located within the Town of Windham. Any person or persons causing snow to obstruct a fire hydrant shall immediately clear said fire hydrant. Failure to do so shall result in clearing of the fire hydrant by the Windham Fire – Rescue Department at the cost of the property owner. The cost of such violation shall be a fee schedule establish by order of the Town Council.

Section 01.09.03

Violations of this code shall be enforced pursuant to 30-A M.R.S.A. §4452.

Article 01.10 Appeal Process

This article establishes the process for any person wishing to appeal a decision of the AHJ.

Section:01.10.01

Appeals of decisions under this code shall be to the Board of Appeals. The appeals process shall be the same as established in the town's Land Use Ordinance.

Appendix A

BOCA Code (1999 edition) Chapter 3, “Use or Occupancy”

Appendix B

Use Groups Quick Reference Guide

This guide is an overview and quick reference for the Use Groups as it pertains to the Town of Windham's Fire Prevention Code. Please keep in mind that there may definitions, tables, and exceptions in the Appendix for a given Use Group. For use Group details please refer to Appendix A.

Use Group A. Assemblies. Places where the public meets.

Buildings and structures included but not limited to:

A-1 Intended for the production and view of performing arts or motion pictures, which usually provide fixed seats, included theaters, motion picture theaters, and television and radio studios admitting audiences

A-2 Dance Halls, nightclubs without theatrical stages, and ballrooms are included.

A-3 With or without Auditoriums where people assemble for amusement, entertainment, theatrical stages, libraries, restaurants, and museums.

A-4 For worship purposes, or other religious practices.

A-5 Utilized for outdoor assembly. Grandstands, bleachers, coliseums, stadiums, amusement park structures, and fair or carnival structures.

Use Group B. Businesses. Building which are occupied for business transactions.

Buildings and structures included but not limited to:

Airports, animal hospitals, automotives show rooms, banks, barber shops, car washes, civic administration, clinics outpatient, dry cleaners, fire station, florists, laboratories and research, laundries, police stations, post offices, print shops, radio and television stations.

Use Group E. Educational. Public or private schools.

Buildings and structures included but not limited to:

All schools K thru 12. Note: pre-schools may fall under residential daycare or care facilities, and or maybe classified as a Use Group R, I or M depending on different factors.

Use Group F. Factory and Industrial.

Building and structures included but not limited to.

Machine shops, wood shops, assembly plants, manufacturing and industrial building or structures.

F-1 Moderate Hazards see BOCA table 306.3. See Appendix A page 19

F-2 Low Hazards see BOCA table 306.2. See Appendix A page 19

Use Group H. High Hazards. Building or structures housing high hazards.

Buildings and structures included but not limited to:

H-1 Detonation hazards, such as explosives. Explosives used for blasting.

H-2 Deflagration hazards, such as flammable liquids, combustible dusts, flammable gasses, organic peroxides.

H-3 Buildings or structures that contain materials that readily support combustion. Aerosols, flammable solids, bulk storage of tires, combustible fibers, organic peroxides.

H-4. All buildings containing materials that are health hazards. Included but not limited to: Corrosives, highly toxic materials, irritants, and radioactive materials.

Note: There are many definitions to this Use Group. Please refer to Appendix A or Chapter 3 of the 1999 edition of BOCA. Page 24 Table 307.8 (1), and Page 25 Table 307.8 (2)

Use Group I. Institutional.

Buildings and structures included but not limited to:

I-1 Board and care facilities, halfway house, group homes, social rehabilitation facilities, drug or alcohol centers, and convalescences homes.

I-2 Medical, surgical, psychiatric, nursing or custodial care on a 24 hour basis of (6) six or more persons that are not capable of self-preservation. Hospitals, nursing homes, mental health hospitals, and detoxification facilities are included.

I-3 facilities inhabited by more than six persons who are under some restraint or security. Or by persons who are generally incapable of self preservation due to securities measure not under their control. Jails, reformatories, correctional centers, detention centers, pre-release centers would be included.

Note: There are (5) five Occupancy Condition criteria for this Use Group. Please refer to Appendix A or Chapter 3 of the 1999 edition of BOCA. Page 28.

Use Group M. Mercantile.

Buildings and structures included but not limited to:

Which are occupied for display ad sales proposes involving stocks of goods, wares, or merchandise, and which is open to the public. Retail stores, automotive service stations, shops, sales rooms and markets are included.

Use Groups R. Residential.

Buildings and structures included but not limited:

R-1 Hotels, motels, boarding houses, and similar buildings arranged for shelter and sleeping accommodations for more than five occupants who are transient in nature, occupying the facilities for a period of less than 30 days.

R-2 All multi-family dwellings having more than two dwelling units, and similar buildings arranged for shelter and sleeping accommodations in which occupants are primarily not transient in nature.

R-3 One or Two family dwelling units including not more than (5) five lodgers or borders per family.

R-4 One or two family dwellings not more that three stories in height.

Use Group S. Storage.

Buildings are structures included but not limited to:

All buildings or structures, which are primarily used for the storage of goods, wares or merchandise. Warehouses, storehouses, and freight depots are included.

S-1 Moderate hazard storage.

S-2 Low hazard storage

Note: Please refer to Appendix A or Chapter 3 of the 1999 edition of BOCA. Page 27 Table 311.2, and 311.3

Use Group U. Utility and Miscellaneous

Buildings and structures included but not limited to:

Agricultural buildings, barns, carports, grain silos, stables, livestock shelters, detached private garages. Green houses.

Appendix C

Areas Where Open Burning is Prohibited

This is a list of streets and locations where open burning is prohibited because of nuisance and health risks associated with the smoke conditions.

The list is current as of February 4, 2010

Baxter Woods	Baxter Woods Trail	North District
Brookhaven	Arcadia Drive	North District
	Brookhaven Drive	North District
	Sylvan Avenue	North District
	Gromble Way	North District
	Peavey Avenue	North District
Collinwood Park	Collinwood Circle	North District
	Runningbrook Drive	North District
	Wedgewood Avenue	North District
Roosevelt Trail	Prairie Way	North District
	Roosevelt Trail (Northerly side of Roosevelt Trail from Dalten Pines to Commons Avenue)	North District
Pinewood Acres	Lucmick Avenue	North District
	Firwood Avenue	North District
	Redwood Drive	North District
	Chipmunk Drive	North District
	Elmwood Drive	North District
	Sprucewood Drive	North District
	Maplewood Drive	North District
	Birchwood Drive	North District
	Chestnut Drive	North District
Tall Pines	Misty Drive	North District
	Eric Road	North District
Varney Mill Estates	Forbes Lane	North District
	Shady Lane	North District
	Stagecoach Lane	North District
	Acorn Lane	North District

Cottage Road

Cottage Road (from Falmouth Road to
To Abbadabba Lane)
Brentwood Road
Upper Beach Road
Lower Beach Road
Orchard Road

East Windham
East Windham
East Windham
East Windham
East Windham