

From: Mark T. Arienti
Sent: Tuesday, June 30, 2020 4:56 PM
To: Jennifer Curtis
Cc: Dustin Roma
Subject: Subdivision Amendment Application Woodside Condominium Retirement Community

Jenn,

I reviewed the above applications and plan for the amendment to the Woodside Condominium Retirement Community (dated 6/22/20) and understand that the applicant would like 6 units along proposed Unity Lane to be moved from Phase 2 into Phase 1. The one question/clarification that would be helpful is to indicate more clearly what infrastructure will be built as part of the amendment. The Amended Subdivision plan shows the 6 units, the road and a call-out for the leach fields, but there is no indication what stormwater infrastructure will be built as well as other road features such as the cross-walk from the sidewalk along Unity over to Conifer Drive. Will these items be part of the amended plan. Please clarify.

Thanks,

Mark

Mark Arienti, P.E., Town Engineer
Town of Windham
8 School Road
Windham, ME 04062

office: (207) 894-5900 x 6124
cell: (207) 712-1359
fax: (207) 892-1916
www.windhammaine.us