

Stephen J. Puleo

From: Mark T. Arienti
Sent: Thursday, June 24, 2021 4:45 PM
To: Stephen J. Puleo
Subject: RE: Gambo Road Waiver 812.E.1.(f) request

Steve,

Another item that I should mention is that the Applicant's submittal did not include any plan outlining housekeeping and maintaining measures for the underdrain soil filter and stone drip edge filter to ensure that it continues to operate as designed.

Mark

From: Stephen J. Puleo <sjpuleo@windhammaine.us>
Sent: Wednesday, June 23, 2021 1:24 PM
To: Mark T. Arienti <mtarienti@windhammaine.us>
Subject: RE: Gambo Road Waiver 812.E.1.(f) request

Thanks, Mark!

From: Mark T. Arienti <mtarienti@windhammaine.us>
Sent: Wednesday, June 23, 2021 1:23 PM
To: Stephen J. Puleo <sjpuleo@windhammaine.us>
Subject: RE: Gambo Road Waiver 812.E.1.(f) request

Steve,

Yes, based on the reasons they provided in their 6/22/21 response including the addition of the filter sock along the fire truck access, I do support the waiver for treatment to less than the Ch. 500 standards,

Mark

From: Stephen J. Puleo <sjpuleo@windhammaine.us>
Sent: Wednesday, June 23, 2021 1:02 PM
To: Mark T. Arienti <mtarienti@windhammaine.us>
Subject: Gambo Road Waiver 812.E.1.(f) request

Hi Mark,

Do you support the waiver request for treatment less than Chapter 500 standards for cultivation facility? If so, just let me know.

Thank you.

Best,

Steve Puleo, Town Planner



Town of Windham
8 School Road
Windham, ME 04062

office: (207) 894-5900 x 6123
cell : 207-712-1069
fax: (207) 892-1916
www.windhammaine.us

NOTICE: Under Maine's Freedom of Access ("Right to Know") law, documents – including emails – in the possession of public officials about town business are considered public records. This means if anyone asks to see it, we are required to provide it. There are very few exceptions. We welcome citizen comments and want to hear from our constituents, but please keep in mind that what you write in an email is not private and will be made available to any interested party.